

Confirmation

LEED v4

On 30 June 2021, Eurofins Product Testing A/S received a sample of a levelling compound with the product name:

Sikafloor[®]-300 Level (GR)

supplied by

Sika Hellas ABEE

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000 and EN 16516 testing standards (See test report no. 392-2021-00334902_G_EN).

The test results of the tested sample indicate that the product qualifies for LEED V4 projects outside the US by showing compliance with the specifications for VOC emissions by complying with:

VOC emissions specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects outside the US:

- The requirements of EMICODE (EC1 PLUS), version of April 2020, with the additional formaldehyde limit of 10 µg/m³ after 28 days.

19 August 2021



Peter Alexander Skov
Analytical Chemist, MSc. Eng. Chemistry



Janne Rothmann Norup
Analytical Service Manager

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.