

# Attestation

## LEED v4, v4.1 BETA, and v5

On the 7<sup>th</sup> of July 2025, Eurofins Product Testing A/S received a sample a screed of with the product name:

**Sika MonoTop®-4012**

supplied by

**Sika Services AG**

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, EN 16516, CDPH 01350, and ASTM D2369 testing standards (See test report no. 392-2025-00352803\_H\_EN and no. 392-2025-00352806\_XG\_EN).

**The test results of the tested sample indicate that the product qualifies for LEED v4, LEED v4.1 BETA (February 2024), and LEED v5 (April 2025) projects globally by showing compliance with the specifications for VOC emissions and VOC content by complying with:**

**VOC emissions specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects globally:**

- The requirements of LEED v4, LEED v4.1 BETA (February 2024) and LEED v5 (April 2025) by: CDPH-IAQ (California Department of Public Health (CDPH) Standard Method v1.2-2017); and a TVOC below 0.5 mg/m<sup>3</sup> in both office and classroom.

**VOC content specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects globally:**

- The requirements of LEED v4 and LEED v4.1 BETA (February 2024): South Coast Air Quality Management District (SCAQMD) Rule 1113 (2016) for 'Default Material' having a VOC content below 50 g/L.

22 August 2025



Tobias Sandbaek  
Analytical Service Manager

*LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.*