

Attestation

LEED v5

On the 5th of February 2026, Eurofins Product Testing A/S received a sample of a screed material with the product name:

Sika® ViscoCrete® Techno-10+

supplied by

SIKA HELLAS ABEE

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000 and EN 16516 testing standards (See test report no. 392-2026-00232901).

The test results of the tested sample indicate that the product qualifies for LEED v5 (November 2025) projects in Europe by showing compliance with the specifications for VOC emissions by complying with:

VOC emissions specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects in Europe:

- The requirements of LEED v5 (November 2025) by complying with the German AgBB Testing and Evaluation Scheme (2024), showing an overall R-value ≤ 1 , having a TVOC according to EN 16516 $\leq 1,000 \mu\text{g}/\text{m}^3$, a sum of VOC without LCI $< 100 \mu\text{g}/\text{m}^3$, and a formaldehyde emission $\leq 10 \mu\text{g}/\text{m}^3$; all after 28 days.

4 May 2026



Tobias Sandbaek
Analytical Service Manager



Isabella B. Larsen
Analytical Service Manager

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.