

Attestation

LEED v4 and v4.1 BETA

On the 5th of February 2026, Eurofins Product Testing A/S received a sample of screed material with the product name:

Sika® ViscoCrete®-454 Ultra

supplied by

SIKA HELLAS ABEE

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000 and EN 16516 testing standards (See test report no. 392-2026-00073107_G_EN).

Deviations from the referenced test methods were registered. (See section 4.4 in test report no. 392-2026-00073107_G_EN).

The test results of the tested sample indicate that the product qualifies for LEED v4 and LEED v4.1 BETA (November 2025) projects in Europe by showing compliance with the specifications for VOC emissions and by complying with:

VOC emissions specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects in Europe:

- The requirements of LEED v4 and LEED v4.1 BETA by complying with:
 - The requirements of EMICODE (EC1 PLUS), version of April 2020, with the additional formaldehyde limit of 10 µg/m³ after 28 days.

16 April 2026



Tobias Sandbaek
Analytical Service Manager



Claus Bonde
Analytical Service Manager

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.